


**CULVERT LINK SLAB NOTES:**


1. REFER TO GENERAL TOLERANCES UNO
2. ALL LIFTING POINTS TO BE USED WHEN LIFTING
3. MINIMUM STRENGTH OF CONCRETE SHALL BE 25MPA AT THE TIME OF LIFTING
4. NOMINAL COVER TO REINFORCEMENT - 35MM
5. REFER TO ANCON LIFTING ARRANGEMENT PLAN
6. BOX CULVERTS COMPLIES TO AS1597.2-2013




PLAN VIEW



ISOMETRIC VIEW



ELEVATION VIEW



END VIEW

UNCONTROLLED DOCUMENT WHEN PRINTED

**TOLERANCE NOTES:**

1. CONCRETE TOLERANCES TO BE INCONJUNCTION / ACCORDANCE WITH AS3600 - CONCRETE STRUCTURES
2. WHEN A BROOME FINISH IS REQUIRED THE GENERAL TOLERANCE SUPERCEEDS THE FLATNESS TOLERANCE
3. WALL THICKNESS - DIMENSION AS NOTED IS MINIMUM THICKNESS ONLY
4. CONCRETE GRADE - 40MPA UNLESS NOTED OTHERWISE
5. DIMENSIONS ARE NOT INCLUSIVE OF SEALANTS OF JOINTS
6. SURFACE FINISH - CLASS 4 (AS3610.1)

| Rev | DESCRIPTION | DATE | BY | APPROVED |
|-----|-------------|------|----|----------|
| 3   |             |      |    |          |
| 2   |             |      |    |          |
| 1   |             |      |    |          |

| GENERAL TOLERANCES |              | REVISION CONTROL                     |   |
|--------------------|--------------|--------------------------------------|---|
| NOMINAL:           | UP TO 1000mm | 1M AND ABOVE                         | FLATNESS: (NOT INCLUDING BROOME FINISH) |
| TOLERANCE:         | ±5mm         | 1mm IN 200mm UP TO A MAXIMUM OF 20mm | ±4mm PER 1M WIDTH IN 1M LENGTH          |

|                             |
|-----------------------------|
| CHK / APPR:<br>Revee Lein   |
| DATE:<br>M. Orozco          |
| RPEQ DOCUMENT #:            |
| WEIGHT:<br>3354.85Kg        |
| MATERIAL:<br>CONCRETE 50MPA |
| IRF REF:                    |

**Infrastructure Products Australia**  
A CRH COMPANY

HEAD OFFICE:  
1 REEVES COURT  
BREAKWATER, VIC 3219  
1800 065 356

ENGINEERING & DEVELOPMENT:  
91 STRADBROKE STREET  
HEATHWOOD, QLD 4110  
(07) 3714 0444

|   |
|---|
| DRAFTED DATE:<br>24/01/2022                 |
| DRAFTED BY:<br>DPRUSAC                      |
| DATE LAST SAVED:<br>4/07/2022               |
| LAST SAVED BY:<br>ROROZCO                   |
| DRAWN TO AS 1100<br>DO NOT SCALE FROM SHEET |

|   |                           |                             |
|---|---------------------------|-----------------------------|
| PART/PRODUCT #<br>TMR LINK SLABS                            | QUOTE #                   | ORDER #                     |
| REINFORCEMENT COMPUTATION                                   | PIT #<br>50207205         | ITEM TYPE<br>RCBC LINK SLAB |
| CLIENT<br>CUBIS SYSTEMS                                     | PROJECT DESC<br>LINK SLAB |                             |
| DRAWING NAME<br>LINK SLAB TMR 1800-2A 2400mm NOMINAL LENGTH | DRAWING #<br>50207205     | REV.<br>0                   |
| PAGE<br>1 / 1   | SHEET SIZE<br>A3          | SCALE<br>1:25               |