


CONCRETE PRODUCT NOTE:


1. REFER TO GENERAL TOLERANCES UNO
2. REFER TO DRAWING 522380 GENERAL ARRANGEMENT
3. REFER TO DRAWING 522378-REO FOR REO DEATIL
4. 40MPA FIBRE REINFORCED CONCRETE (FIBRECON MP47@5Kg/M³)
5. ALL LIFTING POINTS TO BE USED WHEN LIFTING
6. MINIMUM STRENGTH OF CONCRETE SHALL BE 25MPA AT THE TIME OF LIFTING
7. COVER TO REINFORCEMENT TO BE 35mm
8. REFER TO ANCON LIFTING ARRANGEMENT PLAN
9. CONCRETE VOLUME (M³) = 0.19

BOM:50202563_CATALOGUE ITEM


ITEM #	QTY	PART #	DESCRIPTION	MATERIAL	VOLUME
1	1	50201039	CONCRETE FIBRE 40MPA	CONCRETE FIBRE 40MPa	0.19
2	4	50201041	EYE ANCHOR GALV 1.3Tx65mm	GALVANIZED STEEL	
3	1	50201101	UNISTRUT ZP 3000mm	GALVANIZED STEEL	



PLAN VIEW




SECTION A-A



END VIEW
BOTH ENDS WITH KNOCKOUTS

50mm DRAIN HOLE AT INTERNAL CORNER



ISOMETRIC VIEW

UNCONTROLLED DOCUMENT WHEN PRINTED

TOLERANCE NOTES:

1. CONCRETE TOLERANCES TO BE INCONJUNCTION / ACCORDANCE WITH AS3600 - CONCRETE STRUCTURES
2. WHEN A BROOM FINISH IS REQUIRED THE GENERAL TOLERANCE SUPERCEDES THE FLATNESS TOLERANCE
3. WALL THICKNESS - DIMENSION AS NOTED IS MINIMUM THICKNESS ONLY
4. CONCRETE GRADE - 40MPA UNLESS NOTED OTHERWISE
5. DIMENSIONS ARE NOT INCLUSIVE OF SEALANTS OF JOINTS
6. SURFACE FINISH - CLASS 4 (AS3610.1)

Rev	DESCRIPTION	DATE	BY	APPROVED
3				
2				
1				

GENERAL TOLERANCES		REVISION CONTROL	
NOMINAL:	UP TO 1000mm	1M AND ABOVE	FLATNESS: (NOT INCLUDING BROOME FINISH)
TOLERANCE:	±5mm	1mm IN 200mm UP TO A MAXIMUM OF 20mm	±4mm PER 1M WIDTH IN 1M LENGTH

CHK / APPR: Lee, Mia	WEIGHT: 454.59Kg
DATE:	MATERIAL: CONCRETE FIBRE 40MPA
RPEQ DOCUMENT #:	IRF REF:

Infrastructure Products Australia
A CRH COMPANY

HEAD OFFICE:
1 REEVES COURT
BREAKWATER, VIC 3219
1800 065 356

ENGINEERING & DEVELOPMENT:
91 STRADBROKE STREET
HEATHWOOD, QLD 4110
(07) 3714 0444

DRAFTED DATE: 26/09/2022	DRAWN TO AS 1100 DO NOT SCALE FROM SHEET
DRAFTED BY: MLEE	
DATE LAST SAVED: 26/09/2022	
LAST SAVED BY: MLEE	

PART/PRODUCT # 50202563	QUOTE #	ORDER #
REINFORCEMENT COMPUTATION	PIT #	ITEM TYPE
CLIENT CUBIS SYSTEMS/AUSPITS	PROJECT DESC CATALOGUE ITEM	
DRAWING NAME PIT CONCRETE BELLTOP 5 LOCK ADAPTABLE TO SUIT COMPOSITE COVER CLASS D	DRAWING # 50202563	REV. 0
PAGE 1 / 1	SHEET SIZE A3	SCALE 1:15