



BOTTOM VIEW

IN 1M LENGTH

Ø30 CLEAR ▼ 9 (RFID LOCATION)

TOLERANCE:

±5mm

TOLERANCE NOTES:

1. CONCRETE TOLERANCES TO BE INCONJUCTION / ACCORDANCE WITH AS3600 - CONCRETE STRUCTURES

2. WHEN A BROOME FINISH IS REQUIRED THE GENERAL TOLERANCE SUPERCEEDS THE FLATNESS TOLERANCE

3. WALL THICKNESS - DIMENSION AS NOTED IS MINIMUM THICKNESS ONLY

4. CONCRETE GRADE - 40MPA UNLESS NOTED OTHERWISE

5. DIMENSIONS ARE NOT INCLUSIVE OF SEALANTS OF JOINTS

6. SURFACE FINISH - CLASS 4 (AS3610.1)

2 Rev. DESCRIPTION DATE APPROVED BY REVISION CONTROL **GENERAL TOLERANCES** FLATNESS: (NOT INCLUDING BROOME FINISH) 1M AND ABOVE UP TO 1000mm

1mm IN 200mm UP TO A MAXIMUM OF 20mm

CA RPEQ DOCUMENT #: 15Kg MATERIAL ±4mm PER 1M WIDTH



CARNGHAM ROAD BALLARAT, VIC 3351 (03) 5335 8741 ENGINEERING & DEVELOPMENT:
91 STRADBROKE STREET
HEATHWOOD, QLD 4110

(07) 3714 0444 THE INFORMATION DISCLOSED IN

A CRH COMPANY

AUSTRALIA TO BE COPIED, REPRODUCED, OR GIVEN TO ANY OTHER PARTY IN ANY FORM AND THAT ALL COPYRIGHT, DESIGNS AND PATENTS VEST IN CUBIS SYSTEMS AUS.

DRAFTED DATE:	PART/PRODUCT #	QUOTE #	ORDER #	
28/05/2018	50202575			
DRAFTED BY:	REINFORCEMENT COMPUTATION	PIT #	ITEM TYPE	
A.CHAO				
DATE LAST SAVED:	CLIENT	•	•	
4/11/2020	CUBIS SYSTEMS/AUSPITS			
AST SAVED BY:	PROJECT DESC			
CABEYSINGH				
E ⊕E	P5 CLASS B (ELECTRICAL)		REV.	

1 / 1

Α3

1:5

50202575