

GENERAL NOTES:

1. CONCRETE GRADE TO BE 50 MPA MINIMUM
2. DESIGN LIFE OF 50 YEARS
MINIMUM EXPOSURE CLASSIFICATION - B2
MINIMUM COVER TO REINFORCEMENT - 40mm
3. DESIGN LIFE OF 100 YEARS
MINIMUM EXPOSURE CLASSIFICATION - B1
MINIMUM COVER TO REINFORCEMENT - 40mm
4. DESIGN CAPACITY OF PITS WITH CLASS L REINFORCEMENT HAS BEEN REDUCED 20%
5. SPLICES IN REINFORCEMENT, UNLESS OTHERWISE NOTED, SHALL BE BY LAPPING AS FOLLOW:
GRADE 500 N8 BARS - MIN. 250mm
GRADE 500 N12 BARS - MIN. 485mm
6. ALLOWABLE SOIL BEARING PRESSURE IS 100KPA


DESIGN LOADS:

1. CLASS D TRAFFIC DESIGN LOAD - AS3996:2019 & AS5100:2017


BOM:AP-EC-CRS99D-ENC 1300x1300x250

ITEM #	QTY.	DESCRIPTION	MATERIAL
1	1	1300x1300x250 CLS D ENCASEMENT	CONCRETE 50MPa
2	4	FOOT ANCHOR 1.3Tx85mm	MS GR-250 GALV
3	1	COVER S-TOP ASY 1PT CLS D DI - 900X900	DUCTILE IRON


GSG99D / CLASS D / 1300x1300x250 ENCASEMENT




PLAN VIEW




END VIEW



SECTION A-A
SCALE 1:10



ISOMETRIC VIEW



SECTION B-B
SCALE 1:10

ISSUED FOR CONSTRUCTION

TOLERANCE NOTES:

1. CONCRETE TOLERANCES TO BE IN CONJUNCTION / ACCORDANCE WITH AS3600 - CONCRETE STRUCTURES
2. WHEN A BROOME FINISH IS REQUIRED THE GENERAL TOLERANCE SUPERCEDES THE FLATNESS TOLERANCE
3. WALL THICKNESS - DIMENSION AS NOTED IS MINIMUM THICKNESS ONLY
4. CONCRETE GRADE - 40MPa UNLESS NOTED OTHERWISE
5. DIMENSIONS ARE NOT INCLUSIVE OF SEALANTS OF JOINTS
6. SURFACE FINISH - CLASS 4 (AS3610.1)

Rev.	DESCRIPTION	DATE	BY	APPROVED
3				
2				
1	UPDATE EPICOR NUMBER	06/08/20	MLEE	

GENERAL TOLERANCES		REVISION CONTROL	
NOMINAL:	UP TO 1000mm	1M AND ABOVE	FLATNESS: (NOT INCLUDING BROOME FINISH)
TOLERANCE:	±5mm	1mm IN 200mm UP TO A MAXIMUM OF 20mm	±4mm PER 1M WIDTH IN 1M LENGTH

CHK / APPR:	C
DATE:	
RPEQ DOCUMENT #:	
WEIGHT:	690Kg
MATERIAL:	
IRF REF:	

Aus Pits

HEAD OFFICE:
1/1 REEVES COURT, BREAKWATER, VIC 3219
P: (03) 5222 4526; F: (03) 5222 1914

THE INFORMATION DISCLOSED IN THIS DOCUMENT IS CONFIDENTIAL AND IS NOT WITHOUT THE EXPRESS CONSENT OF AUSPITS AUSTRALIA TO BE COPIED, REPRODUCED, OR GIVEN TO ANY OTHER PARTY IN ANY FORM AND THAT ALL COPYRIGHT, DESIGNS AND PATENTS VEST IN AUSPITS AUSTRALIA

DRAFTED DATE:	15/07/2020
DRAFTED BY:	MLEE
DATE LAST SAVED:	9/09/2020
LAST SAVED BY:	MLEE

PART/PRODUCT #	QUOTE #	ORDER #
REINFORCEMENT COMPUTATION	PIT #	ITEM TYPE
CLIENT	PROJECT DESC	
ENCASEMENT (CLASS D)		
ENGINEERING COMPUTATION	REV. 1A	
DRAWING # AP-EC-CRS99D-ENC 1300X1300X250	PAGE 1 / 1	SHEET SIZE A3
SCALE 1:20		